

Sudbury Water District
Sudbury, Massachusetts 01776
Request for Proposals (IFB) 19-13
Codjer Lane and Horse Pond Road Water Main Improvements

Notice to All Prospective Bidders

ADDENDUM #1 RELEASED March 22, 2019

Sudbury Water District has issued this addendum for clarification by prospective bidders before the deadline:

1. Page 309:

- B. Valves are to have O-ring seals and a non-rising stem. Valves shall have a 2-inch square operating nut, and be **Open Left (counter-clockwise to open)**.

Replace the highlighted area with "Open Right (Clockwise to open)"

- C. Valves shall be as manufactured by Mueller Company, American Flow Control, or **equal**.

Replace highlighted area with "AVK"

2. Page 310:

- D. Valve boxes shall be cast iron, asphalt coated, sliding type, adjustable, together with cast iron covers with the word "WATER" and a direction-to-open arrow plainly cast in relief on the top surface. A minimum 6-inch overlap is required between sliding sections. The inside diameter of the bottom section shall be at least 5-1/4-inches and shall have a belled base. The top section shall be at least 6-1/8-inches and have top flanges. The bottom section shall be at least 36-inches in length. The top section shall be at least 26-inches in length and have a plain bottom. No three piece combinations shall be acceptable. Valve boxes shall **be manufactured in North America only**.

Replace highlighted area with "Meet AWWA specifications"

3. Page 311:

- I. Hydrants shall be Mueller Co. Centurion Model A-423, American Darling, Model #B62B, or **approved equal**.

Replace highlighted area with "AVK"

- K. Tapping Sleeves shall be manufactured by Mueller Co., Clow Corporation, or approved equal. Tapping sleeves shall match the requirements of the detail on the construction drawings. Tapping valves shall be manufactured by Mueller Company,

Kennedy Valve Manufacturing Company or equal and shall be furnished with one flange end and one mechanical joint end. Valves shall **open left**. The Contractor shall verify the outside diameter of the pipe to be tapped.

Replace the highlighted area with “Open Right”.

4. Page 316:

- C. The curb box shall be of the “Erie” type, cast-iron construction. The curb box shall be tar base enamel coated inside and out and shall be equipped with a 30” stainless steel operating extension rod. The lid shall be of extra heavy cast-iron construction with a brass pentagon plug. Curb stop boxes shall **be manufactured in North America only**.

Replace highlighted area with “Meet AWWA specifications”

The above responses were prepared by or in consultation with:

Vincent Roy, Executive Director

The Sudbury Water District reserves the right to reject any and all bids as determined to be in the best interests of the District and to waive minor informalities.