

SUDBURY WATER DISTRICT  
EAST STREET WATER TREATMENT PLANT (WTP) PFAS TREATMENT  
DWSRF-11383  
ADDENDUM NO. 1

.....

To be considered as part of the contract drawings and specifications for the East Street WTP PFAS Treatment Project, DWSRF-11383.

**NOTIFICATIONS**

1. Optional Pre-bid site walk has been rescheduled to Tuesday, February 20, 2024, at 10:00 AM.
2. Filed Sub-bid opening has been rescheduled to February 27, 2024.

**SPECIFICATIONS**

1. SECTION 26 00 01 Filed Sub Bid Requirements (Electrical)

**REPLACE** Paragraph 1.1.E.1 “Work to be done under this section is primarily shown on the following Contract Drawings: E001, E002, E101, E201; E202; E203; E501; E502 and E601.”

**WITH** “Work to be done under this section is primarily shown on the following Contract Drawings: E001, E002, E101, E201, E202, E501, E502, E601, PV001 and PV601.”

**DELETE** Paragraph 1.1.E.2 “Drawings PV001 AND PV601 are included for coordination.”

**QUESTIONS AND ANSWERS**

Q1: Please confirm that a temporary field office will not be required for this project.

**A1: A temporary field office will not be required for this project.**

Q2: Section 26 00 01 E. 2 lists the PV drawings as coordination. Please advise what this means. Alternate 1 is included on the sub-bid electrical form (but also on the GC form) and solar work is considered electrical work. Please advise who is responsible for both PV001 and PV601.

**A3: The Electrical Filed Sub-bid is responsible for furnishing and installing the PV system complete as indicated on drawings PV001 and PV601. The General Contractor is responsible for furnishing and installing connections to the roof trusses.**

Q3: Are building and trade permit fees for this project waived?

**A3: No, building and trade permit fees will not be waived for this project.**