

**Sudbury Water District
PFAS Analytical Results History**

MassDEP -PFAS Compounds Tested

EPA - PFAS MCL- promulgated April 10, 2024

Sample Site RW/FW

<i>PFHpA</i>	<i>PFHxS</i>	<i>PFOA</i>	<i>PFNA</i>	<i>PFOS</i>	<i>PFDA</i>	<i>MassDEP Limit <20pptTotal</i>
--------------	--------------	-------------	-------------	-------------	-------------	---

<i>PFOA 4 ppt</i>	<i>PFOS 4 ppt</i>	<i>HFPO-DA (Gen x) 1.0 (unitless) Hazard Index</i>	<i>PFBS 1.0 (unitless) Hazard Index</i>	<i>PFHxS 1.0 (unitless) Hazard Index</i>	<i>PFNA 1.0 (unitless) Hazard Index</i>
-----------------------	-----------------------	--	---	--	---

Test Results from 1/30/2020 Report

1	Well # 2A	RW	ND	2.24	5.58	ND	4.77	ND	12.59
2	Well # 3A	RW	2.22	ND	6.52	ND	3.53	ND	12.27
3	Well # 5	RW	ND	ND	ND	ND	ND	ND	ND
4	Well # 7	RW	ND	ND	5.12	ND	4.31	ND	9.43
5	Well # 8A	RW	ND	ND	5.7	ND	2.20	ND	7.90
6	Well # 9	RW	ND	ND	4.63	ND	4.61	ND	9.24
7	Well # 10	RW	2.65	ND	5.51	ND	2.2	ND	10.36

5.58	4.77				
6.52	3.53				
ND	ND				
5.12	4.31				
5.7	2.2				
4.63	4.61				
5.51	2.2				

8	Well # 4	FW	ND	2.62	5.16	ND	2.14	ND	9.92	*
9	Well # 6	FW	ND	ND	5.46	ND	2.92	ND	8.38	*
10	ESWTP	FW	2.25	ND	5.56	ND	2.67	ND	10.48	*
11	RRWTP	FW	ND	1.97	5.19	ND	4.45	ND	11.61	*

5.16	2.14				
5.46	2.92				
5.56	2.67				
5.19	4.45				

Confirmation Results from 2/20/2020 Report

8	Well # 4	FW	ND	3.52	6.04	ND	2.25	ND	11.81	*
9	Well # 6	FW	1.81	2.00	6.24	ND	3.46	ND	13.51	*
10	ESWTP	FW	2.73	ND	6.95	ND	3.28	ND	12.96	*
11	RRWTP	FW	ND	2.19	5.85	ND	4.96	ND	13.00	*

6.04	2.25				
6.24	3.46				
6.95	3.28				
5.85	4.96				

Test Results from 8/10/2020 Report

8	Well # 4	FW	1.6 J	2.12 J	5.27	ND	2.25	ND	7.52	*
9	Well # 6	FW	1.7 J	1.54	5.19	ND	2.97	ND	9.70	*
10	ESWTP	FW	2.66	1.65 J	6.67	ND	3.06	ND	12.39	*
11	RRWTP	FW	1.83 J	1.89 J	6.84	0.837 J	6.33	ND	13.17	*

5.27	2.25				
5.19	2.97				
6.67	3.06				
6.84	6.33				

Test Results from 11/2/2020 Report

1	Well # 2A	RW	1.78 J	3.35	7.5	0.656 J	5.61	ND	16.46
2	Well # 3A	RW	2.68	2.12	8.91	ND	4.8	ND	18.51
3	Well # 5	RW	ND	ND	ND	ND	ND	ND	ND
4	Well # 7	RW	2.05	2.08	5.55	0.596 J	5.7	ND	15.38
5	Well # 8A	RW	1.8	2.41	5.8	ND	2.81	ND	12.82
6	Well # 9	RW	1.91	2.49	4.98	0.649 J	6.35	ND	15.73
7	Well # 10	RW	3.09	1.47 J	7.81	0.589 J	3.39	ND	14.29

7.5	5.61				
8.91	4.8				
ND	ND				
5.55	5.7				
5.8	2.81				
4.98	6.35				
7.81	3.39				

8	Well # 4	FW	1.42 J	2.4	4.48	ND	2.26	ND	9.14	*
9	Well # 6	FW	1.72 J	1.79 J	5.33	ND	2.74	ND	8.07	*
10	ESWTP	FW	2.61	1.77 J	7.53	0.434 J	2.93	ND	13.07	*
11	RRWTP	FW	1.96	2.67	6.2	0.606 J	5.6	ND	16.43	*

4.48	2.26				
5.33	2.74				
7.53	2.93				
6.2	5.6				

Sample Site	RW/FW	PFHpA	PFHxS	PFOA	PFNA	PFOS	PFDA	Total	PFOA	PFOS	HFPO-DA	PFBS	PFHxS	PFNA
Test Results from 11/29/2020 Report														
1	Well # 2A	RW	1.88	3.13	7.22	0.922 J	5.53	ND	17.76	7.22	5.53			
2	Well # 3A	RW	3.15	2.18	9.58	0.429 J	5.26	ND	20.17	9.58	5.26			
3	Well # 5	RW	ND	ND	ND	ND	ND	ND	ND	ND	ND			
4	Well # 7	RW	2.51	2.37	6.7	0.728 J	6.19	ND	17.77	6.7	6.19			
5	Well # 8A	RW	2.31	2.02	6.83	ND	3.17	ND	14.33	6.83	3.17			
6	Well # 9	RW	2.17	2.4	5.28	0.899 J	6.22	ND	16.07	5.28	6.22			
7	Well # 10	RW	3.24	1.24 J	7.83	0.753 J	3.73	ND	14.80	7.83	3.73			
8	Well # 4	FW	1.66 J	2.1	5.27	ND	2.73	ND	10.10	5.27	2.73			
9	Well # 6	FW	1.93	1.74 J	5.46	ND	3.16	ND	10.55	5.46	3.16			
10	ESWTP	FW	2.82	1.77 J	8.24	0.795 J	3.8	ND	14.86	8.24	3.8			
11	RRWTP	FW	2.03	2.43	6.64	0.799 J	5.84	ND	16.94	6.64	5.84			
Test Results from 3/19/2021 Report														
8	Well # 4	FW	2.65	3.06	5.53	ND	2.8	ND	14.04	5.53	2.8			
9	Well # 6	FW	2.67	2.26	6.15	ND	3.52	ND	14.60	6.15	3.52			
10	ESWTP	FW	4.24	2.27	9.51	0.669 J	4.68	ND	20.70	9.51	4.68			
11	RRWTP	FW	2.12	2.83	5.92	0.856 J	5.25	ND	16.12	5.92	5.25			
Test Results from 4/7/2021 Report														
8	ESWTP	FW	2.76	2.07	6.87	0.509 J	3.46	ND	15.16	6.87	3.46			
Test Results from 4/21/2021 Report														
8	Well # 4	FW	1.9	3.03	5.17	ND	2.6	ND	12.70	5.17	2.6			
9	Well # 6	FW	2.23	2.05	5.78	ND	3.59	ND	13.65	5.78	3.59			
10	ESWTP	FW	2.45	2.06	6.28	0.461 J	3.62	ND	14.41	6.28	3.62			
11	RRWTP	FW	1.76 J	2.6	5.32	0.734 J	4.99	ND	12.91	5.32	4.99			
Test Results from 5/26/2021 Report														
8	Well # 4	FW	1.57 J	3.26	5.01	ND	2.22	ND	10.49	5.01	2.22			
9	Well # 6	FW	1.88	2.55	5.84	ND	3.22	ND	13.49	5.84	3.22			
10	ESWTP	FW	2.2	2.16	6.18	ND	3.16	ND	13.70	6.18	3.16			
11	RRWTP	FW	1.43 J	2.63	5.45	.0676 J	4.36	ND	12.44	5.45	4.36			
Test Results from 6/16/2021 Report														
8	Well # 4	FW	1.57 J	2.86	5.68	ND	2.54	ND	11.08	5.68	2.54			
9	Well # 6	FW	1.78	2.16	5.73	ND	3.77	ND	13.44	5.73	3.77			
10	ESWTP	FW	2.61	2.51	7.17	ND	3.5	ND	15.79	7.17	3.5			
11	RRWTP	FW	2.92	3.5	7.43	1.06 J	5.68	ND	19.53	7.43	5.68			
<i>Non-routine Samples for investigation purposes</i>														
0	Hop Brook @ Well	FW	2.62	1.96	8.74	1.13 J	8.12	0.692 J	21.44	8.74	8.12			
0	Stearns Pond	FW	2.59	1.67 J	7.82	1.10 J	6.57	0.675 J	16.98	7.82	6.57			

Sample Site	RW/FW	PFHpA	PFHxS	PFOA	PFNA	PFOS	PFDA	Total
-------------	-------	-------	-------	------	------	------	------	-------

Test Results from 7/26/2021 Report

1	Well # 2A	RW	2.24	2.57	7.9	0.845 J	5.62	ND	18.33
2	Well # 3A	RW	3	1.88	9.67	ND	6.52	ND	21.07
3	Well # 5	RW						ND	ND
4	Well # 7	RW	1.98	1.63 J	5.73	0.591 J	3.65	ND	11.36
5	Well # 8A	RW	1.76 J	1.76 J	5.76	ND	2.68	ND	8.44
6	Well # 9	RW	1.71 J	2.11	5.39	0.765 J	4.96	ND	12.46
7	Well # 10	RW	2.82	1.24 J	6.84	ND	2.74	ND	12.40
8	Well # 4	FW	1.55 J	2.04	5.08	ND	2.12	ND	9.24
9	Well # 6	FW	1.61 J	1.89	5.2	ND	3.14	ND	10.23
10	ESWTP	FW	2.62	1.73 J	6.62	ND	3.15	ND	12.39
11	RRWTP	FW	2.04	2.18	6.8	0.764 J	4.84	ND	15.86

PFOA	PFOS	HFPO-DA	PFBS	PFHxS	PFNA
7.9	5.62				
9.67	6.52				
0	0				
5.73	3.65				
5.76	2.68				
5.39	4.96				
6.84	2.74				
5.08	2.12				
5.2	3.14				
6.62	3.15				
6.8	4.84				

Test Results from 8/25/2021 Report

8	Well # 4	FW	1.59 J	1.96	5.4	ND	1.81	ND	9.17
9	Well # 6	FW	1.70 J	1.59 J	4.99	ND	2.53	ND	7.52
10	ESWTP	FW	2.22	1.65 J	6.32	ND	2.44	ND	10.98
11	RRWTP	FW	1.63 J	1.96	6.12	0.688 J	4.24	ND	12.32

5.4	1.81				
4.99	2.53				
6.32	2.44				
6.12	4.24				

Test Results from 9/23/2021 Report

8	Well # 4	FW	2.04	2.18	6.33	ND	2.37	ND	12.92
9	Well # 6	FW	1.74 J	1.81 J	5.39	ND	2.94	ND	8.33
10	ESWTP	FW	2.52	1.83 J	6.8		2.88	ND	12.20
11	RRWTP	FW	2.05	2.24	6.67	0.857 J	5.29	ND	16.25

6.33	2.37				
5.39	2.94				
6.8	2.88				
6.67	5.29				

Test Results from 10/23/2021 Report

8	Well # 4	FW	2.15	2.54	6.91	ND	2.86	ND	14.46
9	Well # 6	FW	2.12	2.12	6.35	ND	3.67	ND	14.26
10	ESWTP	FW	2.87	2.1	7.99	ND	3.5	ND	16.46
11	RRWTP	FW	2.12	2.52	7.6	0.987 JZ	6.84	ND	19.08

6.91	2.86				
6.35	3.67				
7.99	3.5				
7.6	6.84				

Test Results from 11/21/2021 Report

8	Well # 4	FW	2	2.59	6.56	ND	3.06	ND	14.21
9	Well # 6	FW	1.83 J	1.90 J	5.41	ND	3.31	ND	8.72
10	ESWTP	FW	2.72	2.05	7.19	ND	3.7	ND	15.66
11	RRWTP	FW	1.94 J	2.62	6.79	0.862 J	5.93	ND	15.34

6.56	3.06				
5.41	3.31				
7.19	3.7				
6.79	5.93				

Test Results from 1/4/2022 Report

8	Well # 4	FW	2.12	2.16	6.66	ND	2.45	ND	13.39
9	Well # 6	FW	2.13	1.92 J	5.81	ND	3.08	ND	11.02
10	ESWTP	FW	2.71	1.78 J	6.89	ND	2.96	ND	12.56
11	RRWTP	FW	1.78 J	2.08	6.8	0.855 J	5.46	ND	14.34

6.66	2.45				
5.81	3.08				
6.89	2.96				
6.8	5.46				

	<u>Sample Site</u>	<u>RW/FW</u>	<u>PFHpA</u>	<u>PFHxS</u>	<u>PFOA</u>	<u>PFNA</u>	<u>PFOS</u>	<u>PFDA</u>	<u>Total</u>		<u>PFOA</u>	<u>PFOS</u>	<u>HFPO-DA</u>	<u>PFBS</u>	<u>PFHxS</u>	<u>PFNA</u>
Test Results from 2/3/2022 Report																
8	Well # 4	FW	2.37	3.32	6.31	ND	2.55	ND	14.55	*	6.31	2.55				
9	Well # 6	FW	2.14	2.5	6.53	ND	3.48	ND	14.65	*	6.53	3.48				
10	ESWTP	FW	2.95	2.62	6.89	ND	2.96	ND	15.42	*	6.89	2.96				
11	RRWTP	FW	1.98 J	3.26	6.86	ND	3.41	ND	13.53	*	6.86	3.41				
Test Results from 3/8/2022 Report																
8	Well # 4	FW	2.44	1.94 J	6.28	ND	3.23	ND	11.95	*	6.28	3.23				
9	Well # 6	FW	1.92 J	2.65	5.92	ND	2.54	ND	11.11	*	5.92	2.54				
10	ESWTP	FW	1.91 J	1.76 J	5.58	ND	3.02	ND	8.60	*	5.58	3.02				
11	RRWTP	FW	1.52 J	2.08	5.84	0.669 J	5.47	ND	13.39	*	5.84	5.47				
Test Results from 4/27/2022 Report																
8	Well # 4	FW	1.97 J	2.36	6.24	ND	2.3	ND	10.90	*	6.24	2.3				
9	Well # 6	FW	1.74 J	1.52 J	5.29	ND	3.08	ND	8.37	*	5.29	3.08				
10	ESWTP	FW	2.36	1.56 J	6.35	ND	3.01	ND	11.72	*	6.35	3.01				
11	RRWTP	FW	1.44 J	1.74 J	5.43	0.628 J	5.02	ND	10.45	*	5.43	5.02				
Test Results from 5/31/2022 Report																
8	Well # 4	FW	1.95 J	2.2	5.57	ND	2.13	ND	9.90	*	5.57	2.13				
9	Well # 6	FW	1.96 J	1.78 J	5.96	ND	3.34	ND	9.30	*	5.96	3.34				
10	ESWTP	FW	2.42	1.7 J	6.48	ND	3.26	ND	12.16	*	6.48	3.26				
11	RRWTP	FW	1.64 J	1.97 J	6.02	ND	5.24	ND	11.26	*	6.02	5.24				
Test Results from 6/17/2022 Report																
8	Well # 4	FW	1.84 J	1.86 J	5.67	ND	2.08	ND	7.75	*	5.67	2.08				
9	Well # 6	FW	2.07	1.85 J	5.63	ND	3.16	ND	10.86	*	5.63	3.16				
10	ESWTP	FW	2.52	1.63 J	6.32	ND	3.06	ND	11.90	*	6.32	3.06				
11	RRWTP	FW	1.95 J	1.99 J	6.56	0.811 J	5.12	ND	11.68	*	6.56	5.12				
Test Results from 8/11/2022 Report																
8	Well # 4	FW	1.9 J	2.15	5.47	ND	2.12	ND	9.74	*	5.47	2.12				
9	Well # 6	FW	2.11	1.76	5.7	ND	3.1	ND	12.67	*	5.7	3.1				
10	ESWTP	FW	2.66	1.67 J	6.66	ND	2.91	ND	12.23	*	6.66	2.91				
11	RRWTP	FW	1.92 J	2.06	6.67	0.848 JZ	5.2	ND	13.93	*	6.67	5.2				
Test Results from 8/30/2022 Report																
8	Well # 4	FW	1.73 J	1.84 J	6.26	ND	2.23	ND	8.49	*	6.26	2.23				
9	Well # 6	FW	1.77 J	1.41 J	5.48	ND	2.92	ND	8.40	*	5.48	2.92				
10	ESWTP	FW	2.44	1.57 J	6.52	ND	3.06	ND	12.02	*	6.52	3.06				
11	RRWTP	FW	1.95 J	2.22	6.99	0.976 J	5.97	ND	15.18	*	6.99	5.97				
Test Results from 10/5/2022 Report																
8	Well # 4	FW	1.93 J	2	6.76	ND	2.54	ND	11.30	*	6.76	2.54				
9	Well # 6	FW	1.87 J	1.76 J	6.16	ND	3.31	ND	9.47	*	6.16	3.31				
10	ESWTP	FW	2.67	1.68 J	7.74	ND	3.32	ND	13.73	*	7.74	3.32				
11	RRWTP	FW	1.99 J	2.36	7.45	1.03 J	7.34	ND	17.15	*	7.45	7.34				

	<u>Sample Site</u>	<u>RW/FW</u>	<u>PFHpA</u>	<u>PFHxS</u>	<u>PFOA</u>	<u>PFNA</u>	<u>PFOS</u>	<u>PFDA</u>	<u>Total</u>		<u>PFOA</u>	<u>PFOS</u>	<u>HFPO-DA</u>	<u>PFBS</u>	<u>PFHxS</u>	<u>PFNA</u>
Test Results from 11/3/2022 Report																
8	Well # 4	FW	2.41	2.12	6.72	ND	2.44	ND	13.69	*	6.72	2.44				
9	Well # 6	FW	2.3	1.83 J	5.92	ND	3.88	ND	12.10	*	5.92	3.88				
10	ESWTP	FW	3.04	1.77 J	7.21	0.601 J	3.43	ND	13.68	*	7.21	3.43				
11	RRWTP	FW	2.36	2.4	7.08	1.12 JZ	6.43	ND	18.27	*	7.08	6.43				
Test Results from 1/6/2023 Report																
8	Well # 4	FW	1.92	2.1	6.09	ND	2.86	ND	12.97	*	6.09	2.86				
9	Well # 6	FW	1.84 J	1.65 J	5.36	ND	3.71	ND	9.07	*	5.36	3.71				
10	ESWTP	FW	2.52	1.82 J	6.5	ND	3.69	ND	12.71	*	6.5	3.69				
11	RRWTP	FW	1.52 J	2.12	4.9	0.705 J	5.46	ND	12.48	*	4.9	5.46				
Test Results from 2/1/2023 Report																
8	Well # 4	FW	1.86 J	2	6.35	ND	2.42	ND	10.77	*	6.35	2.42	ND	2.61	2	ND
9	Well # 6	FW	1.90 J	1.50 J	6.12	ND	3.33	ND	9.45	*	6.12	3.33	ND	2.9	1.50 J	ND
10	ESWTP	FW	2.52	1.66 J	7.45	ND	3.35	ND	13.32	*	7.45	3.35	ND	2.74	1.66 J	ND
11	RRWTP	FW	1.51 J	1.84 J	6.26	0.884 JZ	5.01	ND	11.27	*	6.26	5.01	ND	1.95	1.84 J	0.884 JZ
Test Results from 2/28/2023 Report																
8	Well # 4	FW	1.98 J	2.12	5.9	ND	2.52	ND	10.54	*	5.9	2.52	ND	3.78	2.12	ND
9	Well # 6	FW	1.76 J	1.48 J	5.61	ND	3.1	ND	8.71	*	5.61	3.1	ND	3.85	1.48 J	ND
10	ESWTP	FW	2.76	1.62 J	6.96	ND	3.06	ND	12.78	*	6.96	3.06	ND	3.17	1.62 J	ND
11	RRWTP	FW	1.46 J	1.90 J	5.48	0.657 J	4.89	ND	10.37	*	5.48	4.89	ND	2.26	1.90 J	0.657 J
Test Results from 4/5/2023 Report																
8	Well # 4	FW	1.74 J	2.17	6.01	ND	3.22	ND	11.40	*	6.01	3.22	ND	2.28	2.17	ND
9	Well # 6	FW	1.59 J	1.55 J	5.61	ND	3.53	ND	9.14	*	5.61	3.53	ND	2.47	1.55 J	ND
10	ESWTP	FW	2.13	1.79 J	6.4	ND	3.4	ND	11.93	*	6.4	3.4	ND	2.42	1.79 J	ND
11	RRWTP	FW	1.19 J	1.88 J	4.99	0.687 J	4.99	ND	9.98	*	4.99	4.99	ND	1.92 JZ	1.88 J	0.687 J
Test Results from 4/27/2023 Report																
8	Well # 4	FW	1.97 J	2.37	6.23	ND	2.59	ND	11.19	*	6.23	2.59	ND	3.53	2.37	ND
9	Well # 6	FW	1.81 J	1.70 J	6.14	ND	3.69	ND	9.83	*	6.14	3.69	ND	3.87	1.70 J	ND
10	ESWTP	FW	2.51	1.76 J	6.88	ND	3.31	ND	12.70	*	6.88	3.31	ND	3.24	1.76 J	ND
11	RRWTP	FW	1.16 J	2.02	5.16	ND	4.7	ND	11.88	*	5.16	4.7	ND	2.24	2.02	ND
Test Results from 5/30/2023 Report																
8	Well # 4	FW	1.63 J	2.06	5.07	ND	2.06	ND	9.19	*	5.07	2.06	ND	3.04	2.06	ND
9	Well # 6	FW	1.46 J	1.60 J	5.51	ND	3.3	ND	8.81	*	5.51	3.3	ND	3.66	1.60 J	ND
10	ESWTP	FW	2.16	1.56 J	6.28	ND	2.88	ND	11.32	*	6.28	2.88	ND	2.88	1.56 J	ND
11	RRWTP	FW	1.23 J	1.92 J	5.59	ND	4.17	ND	9.76	*	5.59	4.17	ND	2.1	1.92 J	ND
Test Results from 6/14/2023 Report																
8	Well # 4	FW	1.63 J	2.06	5.73	ND	2.26	ND	10.05	*	5.73	2.26	ND	3.04	2.06	ND
9	Well # 6	FW	1.46 J	1.60 J	5.51	ND	3.3	ND	8.81	*	5.51	3.3	ND	3.66	1.60 J	ND
10	ESWTP	FW	2.09	1.77 J	6.28	ND	2.88	ND	11.25	*	6.28	2.88	ND	2.88	1.77 J	ND
11	RRWTP	FW	1.22 J	1.94 J	6.22	0.647 J	4.85	ND	11.07	*	6.22	4.85	ND	2.05	1.94 J	0.647 J

Sample Site	RW/FW	PFHpA	PFHxS	PFOA	PFNA	PFOS	PFDA	Total		PFOA	PFOS	HFPO-DA	PFBS	PFHxS	PFNA	
Test Results from 7/28/2023 Report																
8	Well # 4	FW	1.50 J	2.04	4.75	ND	1.85 J	ND	6.79	*	4.75	1.85 J	ND	2.94	2.04	ND
3	Well # 5	RW	ND	ND	ND	ND	ND	ND	ND		ND	ND				
9	Well # 6	FW	1.62 J	1.87 J	6.12	ND	3.68	ND	9.80	*	6.12	3.68	ND	3.46	1.87 J	ND
10	ESWTP	FW	2.4	1.33 J	6.84	ND	3.47	ND	12.71	*	6.84	3.47	ND	2.8	1.33 J	ND
11	RRWTP	FW	1.28 J	1.26 J	5.33	ND	3.69	ND	9.02	*	5.33	3.69	ND	1.44 J	1.26 J	ND
Test Results from 8/31/2023 Report																
8	Well # 4	FW	1.50 J	1.86 J	5.22	ND	2.25	ND	7.47	*	5.22	2.25	ND	2.33	1.86 J	ND
9	Well # 6	FW	1.70 J	1.70 J	4.98	ND	3.36	ND	8.34	*	4.98	3.36	ND	2.97	1.70 J	ND
10	ESWTP	FW	2.05	1.65 J	5.86	ND	3	ND	10.91	*	5.86	3	ND	2.53	1.65 J	ND
11	RRWTP	FW	1.54 J	2.05	5.83	1.03 J	5.21	ND	13.09	*	5.83	5.21	ND	1.94 J	2.05	1.03 J
Test Results from 9/26/2023 Report																
8	Well # 4	FW	1.68 J	1.86 J	5.39	ND	2.32	ND	7.71	*	5.39	2.32	ND	2.86	1.86 J	ND
9	Well # 6	FW	1.45 J	1.62 J	4.45	ND	3	ND	7.45	*	4.45	3	ND	2.97	1.62 J	ND
10	ESWTP	FW	2.24	1.65 J	5.92	ND	3.24	ND	11.40	*	5.92	3.24	ND	3.09	1.65 J	ND
11	RRWTP	FW	1.57 J	2.01	5.51	0.839 J	5.29	ND	12.81	*	5.51	5.29	ND	2.15	2.01	0.839 J
Test Results from 10/26/2023 Report																
8	Well # 4	FW	2.37	1.94 J	6.3	ND	2.63	ND	11.30	*	6.3	2.63	ND	3.53	1.94 J	ND
9	Well # 6	FW	1.87 J	1.78 J	5.44	ND	3.48	ND	8.92	*	5.44	3.48	ND	3.43	1.78 J	ND
10	ESWTP	FW	2.51	1.61 J	6.37	ND	3.16	ND	12.04	*	6.37	3.16	ND	3.02	1.61 J	ND
11	RRWTP	FW	1.72 J	2.1	6.2	1.03 JZ	6.15	ND	14.45	*	6.2	6.15	ND	2.26	2.1	1.03 JZ
Test Results from 11/27/2023 Report																
10	ESWTP	FW	2.08	1.59 J	5.66	0.605 J	3.3	ND	11.04	*	5.66	3.3	ND	3.09	1.59 J	0.605 J
11	RRWTP	FW	1.58 J	2.02	5.72	1.09 J	5.58	ND	13.32	*	5.72	5.58	ND	2.15	2.02	1.09 J
Test Results from 12/13/2023 Report																
10	ESWTP	FW	2.71	1.69 J	6.83	ND	3.37	ND	12.91	*	6.83	3.37	ND	3.24	1.69 J	ND
11	RRWTP	FW	1.87 J	1.92 J	6.52	1.12 J	6.13	ND	12.65	*	6.52	6.13	ND	2.31	1.92 J	1.12 J
Test Results from 1/23/2024 Report																
10	ESWTP	FW	2.47	1.78 J	8.33	ND	3.5	ND	14.30	*	8.33	3.5	ND	3.17	1.78 J	ND
11	RRWTP	FW	1.20 J	1.88 J	6.2	0.891 J	5.28	ND	11.48	*	6.2	5.28	ND	1.92	1.88 J	0.891 J
Test Results from 2/20/2024 Report																
10	ESWTP	FW	1.99 J	1.51 J	6.08	ND	2.96	ND	9.04	*	6.08	2.96	ND	2.46	1.51 J	ND
11	RRWTP	FW	1.23 J	1.80 J	5.23	0.679 J	4.73	ND	9.96	*	5.23	4.73	ND	2.05	1.80 J	0.679 J

FW - fini .

RW - raw water, pre-treatment

Highest Reading

* Points of entry (finished water) to the distribution which exceed 10 ppt -

J

Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively Identified Compounds (TICs).